

Monthly values of cross-border transmission capacity

PSE S.A. publishes herewith values of cross-border monthly transmission capacity which was calculated with consideration of transmission system security standards and with respect to operating procedure and planning. The publication has been prepared based on monthly transmission grid maintenance schedule. The estimation is preliminary and will be updated according to daily maintenance schedules.

October 2026	PL - DE/CZ/SK (export) [MW]					DE/CZ/SK-PL (import) [MW]					Reason of Congestion (outage)****	
Data	TRM	NTC	ATC*	ZPO**	AAC***	TRM	NTC	ATC*	ZPO**	AAC***	Export	Import
2026-10-01	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	BCS-PLE t.2, VIE-KRA 2
2026-10-02	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	BCS-PLE t.2, VIE-KRA 2
2026-10-03	1100	1300	1300	0	0	1200	2200	2200	0	0	KAP-MUK	BCS-PLE t.2, BCS-KRA t.1
2026-10-04	1100	1300	1300	0	0	1200	2200	2200	0	0	KAP-MUK	BCS-PLE t.2, BCS-KRA t.1
2026-10-05	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	BCS-PLE t.2, VIE-KRA 1, BCS-KRA t.1
2026-10-06	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	BCS-PLE t.2, VIE-KRA 1, BCS-KRA t.1
2026-10-07	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	BCS-PLE t.2, VIE-KRA 1
2026-10-08	1100	1300	1300	0	0	1200	2200	2200	0	0	KAP-MUK	BCS-PLE t.2
2026-10-09	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-10	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-11	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-12	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-13	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-14	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-15	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-16	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA

2026-10-17	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-18	1100	1100	1100	0	0	1200	2300	2300	0	0	KAP-MUK, RZE-KRI	GOR-KRA
2026-10-19	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	GOR-KRA, VIE-KRA 2
2026-10-20	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	GOR-KRA, VIE-KRA 2
2026-10-21	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	GOR-KRA, VIE-KRA 2
2026-10-22	1100	1100	1100	0	0	1200	2000	2000	0	0	KAP-MUK, RZE-KRI	GOR-KRA, VIE-KRA 2
2026-10-23	1100	1100	1100	0	0	1200	2000	2000	0	0	KAP-MUK, RZE-KRI	GOR-KRA, VIE-KRA 2
2026-10-24	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-25	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-26	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	GOR-KRA, VIE-KRA 1
2026-10-27	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	GOR-KRA, VIE-KRA 1
2026-10-28	1100	1300	1300	0	0	1200	2000	2000	0	0	KAP-MUK	GOR-KRA, KRA-MON
2026-10-29	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-30	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA
2026-10-31	1100	1300	1300	0	0	1200	2300	2300	0	0	KAP-MUK	GOR-KRA

* Available transfer capacity taking into account yearly allocated capacity ($ATC = NTC - AAC_{\text{yearly}}$).

** Volume of capacity offered in monthly auction coordinated by Joint Allocation Office S.A. Regarding export, the volume is determined taking into account the calculated NTCs and the difference between surplus of power available for TSO, and the required surplus of power to be available for TSO, which according to IRIESP equals 18% of demand to be covered by national power plants.
Regarding import, the volume is determined taking into account the calculated NTCs and the difference between negative reserve level, and the required negative reserve level.

*** Transmission capacity allocated in monthly auction coordinated auction by Joint Allocation Office S.A. (values updated after the end of an allocation process)

**** Planned maintenance of transmission network elements will be updated according to daily maintenance schedules.