Monthly values of cross-border transmission capacity

PSE S.A. publishes herewith values of cross-border monthly transmission capacity which was calculated with consideration of transmission system security standards and with respect to operating procedure and planning. The publication has been prepared based on monthly transmission grid maintenance schedule. The estimation is preliminary and will be updated according to daily maintenance schedules.

November 2026	PL - DE/CZ/SK (export) [MW]					DE/CZ/SK-PL (import) [MW]					Reason of Congestion (outage)****	
Data	TRM	NTC	ATC*	ZPO**	AAC***	TRM	NTC	ATC*	ZPO**	AAC***	Export	Import
2026-11-01	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-02	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-03	1300	900	900	0	0	1400	1600	1600	0	0	ALB-DET	BCS-KRA t.1
2026-11-04	1300	900	900	0	0	1400	1500	1500	0	0	ALB-DET	HRD-ROE 1, BCS-KRA t.1
2026-11-05	1300	900	900	0	0	1400	1500	1500	0	0	ALB-DET	HRD-ROE 1, BCS-KRA t.1
2026-11-06	1300	900	900	0	0	1400	1600	1600	0	0	ALB-DET	BCS-KRA t.1
2026-11-07	1300	900	900	0	0	1400	1600	1600	0	0	ALB-DET	BCS-KRA t.1
2026-11-08	1300	900	900	0	0	1400	1600	1600	0	0	ALB-DET	BCS-KRA t.1
2026-11-09	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-10	1300	0	0	0	0	1400	1900	1900	0	0	ALB-DET, WIE AT3, NOS-WIE	
2026-11-11	1300	0	0	0	0	1400	1900	1900	0	0	ALB-DET, WIE AT3, NOS-WIE	
2026-11-12	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET, WIE AT3	
2026-11-13	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET, WIE AT3	
2026-11-14	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-15	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-16	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	

2026-11-17	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-18	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-19	1300	900	900	0	0	1400	1900	1900	0	0	ALB-DET	
2026-11-20	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-21	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-22	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-23	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-24	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-25	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-26	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-27	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-28	1300	1100	1100	0	0	1400	1600	1600	0	0		KRA-MON4
2026-11-29	1300	1100	1100	0	0	1400	1900	1900	0	0		
2026-11-30	1300	1100	1100	0	0	1400	1800	1800	0	0		MIK-POL t.2

* Available transfer capacity taking into account yearly allocated capacity ($ATC=NTC-AAC_{yearly}$).

** Volume of capacity offered in monthly auction coordinated by Joint Allocation Office S.A. Regarding export, the volume is determined taking into account the calculated NTCs and the difference between surplus of power available for TSO, and the required surplus of power to be available for TSO, which according to IRiESP equals 18% of demand to be covered by national power plants.
Regarding import, the volume is determined taking into account the calculated NTCs and the difference between negative reserve level, and the required negative reserve level.

*** Transmission capacity allocated in monthly auction coordinated auction by Joint Allocation Office S.A. (values updated after the end of an allocation process)

**** Planned maintenance of transmission network elements will be updated according to daily maintenance schedules.