

Offered Capacity
Monthly auction – April 2018
Technical profile PSE – (50HzT+CEPS+SEPS)

Data	A out (export) [MW]			A in (import) [MW]			Reason of Congestion (outage)	
	NTC	AAC*	Offered Capacity**	NTC	AAC*	Offered Capacity	Export	Import
2018-04-01	1600	0	0	0	0	0		
2018-04-02	1600	0	0	0	0	0	BUJ-BYC	
2018-04-03	1400	0	0	0	0	0	BUJ-BYC, HRD-CHR	
2018-04-04	1300	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV	
2018-04-05	1300	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV, LMA-SNV	
2018-04-06	1300	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV	
2018-04-07	1300	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV	
2018-04-08	1300	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV	
2018-04-09	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV, ALB-DBN	
2018-04-10	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV, ALB-DBN	
2018-04-11	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, LEM-SNV, ALB-DBN	
2018-04-12	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, ALB-DBN	MIK-CRN
2018-04-13	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, ALB-DBN	MIK-CRN
2018-04-14	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, ALB-DBN	MIK-CRN
2018-04-15	700	0	0	0	0	0	BUJ-BYC, HRD-CHR, ALB-DBN	MIK-CRN
2018-04-16	1400	0	0	0	0	0	BUJ-BYC, HRD-CHR	
2018-04-17	1400	0	0	0	0	0	BUJ-BYC, HRD-CHR	
2018-04-18	1400	0	0	0	0	0	BUJ-BYC, HRD-CHR	
2018-04-19	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-20	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-21	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-22	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-23	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-24	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-25	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-26	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-27	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-28	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-29	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	
2018-04-30	500	0	0	0	0	0	HRD-CHR, BUJ-LIS, KOP-LIS	

* - Transmission capacity allocated in yearly coordinated auction by Joint Allocation Office S.A.

** - Volume of capacity offered in monthly auction (export). The volume is determined taking into account the calculated NTCs and the difference between surplus of power available for TSO, and the required surplus of power to be available for TSO, which according to IRIESP equals 17% of demand to be covered by national power plants.