

Forecast values of cross-border transmission capacity for 2019
Export Direction

PSE S.A. publishes herewith forecast of cross-border transmission capacity which was calculated with consideration of transmission system security standards and with respect to operating procedure and planning. The forecast has been prepared based on monthly transmission grid maintenance schedule. The estimation is preliminary and will be updated according to monthly maintenance schedules.

PL - DE/CZ/SK (Export)						
	TTC	TRM	NTC	Offered Capacity*	Period	Reason of Congestion (outage)
1	1800	600	1200	0	01.01 - 06.01	
2	1300/1000*	600	700/400*	0	07.01 - 19.01	Krosno Iskrzynia - Tarnów, Sokolnice - Prosenice t.1 i t.2
3	1700	600	1100	0	20.01 - 27.01	Sokolnice - Prosenice t.1 i t.2
4	1300/1000*	600	700/400*	0	28.01 - 09.02	Krosno Iskrzynia - Tarnów, Sokolnice - Prosenice t.1 i t.2
5	1700	600	1100	0	10.02 - 15.02	Sokolnice - Prosenice t.1 i t.2
6	1800	600	1200	0	16.02 - 17.02	
7	1300/1000*	600	700/400*	0	18.02 - 02.03	Krosno Iskrzynia - Tarnów
8	1800	600	1200	0	03.03	
9	1400	600	800	0	04.03 - 08.03	Hradec - Chrast, V.Kapusany - Mukachevo
10	1600	600	1000	0	09.03 - 10.03	linii Hradec - Chrast
11	1500	600	900	0	11.03	Hradec - Chrast, Lipt.Mara - Sp.Nova Ves, Sp.Nova Ves - Lemesany
12	1500	600	900	0	12.03 - 15.03	Hradec - Chrast, Sp.Nova Ves - Lemesany
13	1800	600	1200	0	16.03 - 17.03	
14	1500	600	900	0	18.03 - 22.03	Schmolln - Dresden/Sud t.1 i t.2, Prestice-Chrast
15	1600	600	1000	0	23.03 - 24.03	Schmolln - Dresden/Sud t.1 i t.2
16	0	0	0	0	25.03 - 29.03	Krosno Iskrzynia - Lemesany t.1 i t.2, Schmolln - Dresden/Sud t.1 i t.2
17	1800	600	1200	0	30.03 - 31.03	
18	2000	900	1100	0	01.04 - 04.04	
19	1600	900	700	0	05.04	Dobrzeń - Albrechtice
20	2000	900	1100	0	06.04 - 11.04	
21	1900	900	1000	0	12.04 - 14.04	Krosno Iskrzynia - Rzeszów
22	1600	900	700	0	15.04 - 18.04	Nosovice - Albrechtice
23	2000	900	1100	0	19.04 - 01.05	
24	1900	900	1000	0	02.05 - 19.05	Hradec - Roehrsdorf t.1 i t.2
25	2000	900	1100	0	20.05 - 09.06	
26	1400	900	500	0	10.06 - 17.06	Bujaków - Liskovec
27	1400	900	500	0	18.06 - 22.06	Bujaków - Liskovec, Kopanina - Liskovec
28	1400	900	500	0	23.06 - 28.06	Kopanina - Liskovec
29	2000	900	1100	0	29.06 - 30.06	
30	1000	900	100	0	01.07 - 04.07	Wielopole - Nosovice
31	2000	900	1100	0	05.07 - 12.07	
32	1200	900	300	0	13.07 - 31.07	Nosovice - Varin
33	1100	900	200	0	01.08 - 11.08	Nosovice - Varin, Cebin - Mirovka
34	1700	900	800	0	12.08 - 14.08	Cebin - Mirovka, Otrokovice - Prosenice, Varin - Sucany

35	1700	900	800	0	15.08 - 16.08	Cebin - Mirovka, Otrokovice - Prosenice, Hradec - Mirovka, Varin - Sucany
36	1800	900	900	0	17.08 - 15.09	Cebin - Mirovka, Otrokovice - Prosenice, Hradec - Mirovka
37	1900	900	1000	0	16.09 - 20.09	Cebin - Mirovka, Otrokovice - Prosenice
38	1900	900	1000	0	21.09 - 22.09	Cebin - Mirovka
39	1800	900	900	0	23.09 - 25.09	Cebin - Mirovka, Lipt.Mara - Sp.Nova Ves
40	1900	900	1000	0	26.09 - 27.09	Cebin - Mirovka, Lipt.Mara - Sp.Nova Ves, Lemesany - Sp.Nova Ves
41	1900	900	1000	0	28.09 - 20.10	Cebin - Mirovka
42	1800	900	1000	0	21.10 - 25.10	Cebin - Mirovka, Nosovice - Prosenice
43	1800	900	900	0	26.10 - 27.10	Cebin - Mirovka, Liskovec - Prosenice t.1 i t.2
44	1900	900	1000	0	28.10 - 31.10	Cebin - Mirovka, Liskovec - Prosenice t.1 i t.2, V.Kapusany - Mukachevo
45	1600	600	1000	0	01.11 - 29.11	Cebin - Mirovka, Liskovec - Prosenice t.1 i t.2, V.Kapusany - Mukachevo
46	1600	600	1000	0	30.11	Cebin - Mirovka, Liskovec - Prosenice t.1 i t.2
47	1600	600	1000	0	01.12 - 04.12	Liskovec - Prosenice t.1 i t.2
48	1800	600	1200	0	05.12 - 31.12	

* - temperature 0⁰C/ 10⁰C

** - Volume of capacity to be allocated in yearly auction by Joint Allocation Office S.A. The volume is determined taking into account the calculated for given timeframes NTCs and the difference between surplus of power available for TSO, and the required surplus of power to be available for TSO, which according to IRiESP equals 18% of demand to be covered by national power plants.

**Forecast values of cross-border transmission capacity for 2019
Import Direction**

DE/CZ/SK - PL (Import)						
	TTC	TRM	NTC	Offered Capacity**	Period	Reason of Congestion (outage)
1	2100	2100	0	0	1.01 - 31.03	
2	2200	2200	0	0	1.04 - 31.10	
3	2100	2100	0	0	1.11 - 31.12	

** - Volume of capacity to be allocated in yearly auction by Joint Allocation Office S.A.